



Riverside County Fire Department

Office of the Fire Marshal

2300 Market St., Ste. 150, Riverside, CA 92501 Ph. (951) 955-4777 Fax (951) 955-4886

Guideline

Title: Large Family Day-care		
Guideline: # G08-004	Effective Date: 03/17/2008	Revised Date: 08/16/2018
Code References: 2016 California Building Code, Chapter 4, Section 455		

Purpose:

This information bulletin has been developed to assist applicants, architects, and contractors in determining the minimum requirements for a large family day care.

Scope:

This bulletin is intended to ensure compliance with the appropriate requirements for a large family day care which are found in the California Code of Regulations CCR, Title 19, as well as the 2016 California Fire Code (CFC) and 2016 California Building Code (CBC). Plans not conforming to the requirements listed herein will be returned as incomplete.

Contact Information:

For additional information regarding a Large Family Day Care please call your local Fire Marshal office.

Occupancy Classifications:

Every large-family day care home shall comply with the provisions for Group R-3 occupancies. CBC 455.

Submittal Requirements:

Site and floor plans shall be submitted to the local Riverside County Fire Department (RCFD) Office of the Fire Marshal for review, along with the Form 850 from Community Care Licensing, at the time of final fire inspection request. The plans must include the building address, occupancy classification of large family day care, and the location of smoke detectors, fire alarms, exit doors and gates.

Provide a detailed letter identifying all intended use and operations of the facility. Include room locations for children.

Use this guideline to ensure that your plans have at least the minimum amount of information required for a review. It may be necessary to provide additional information beyond what is requested in this guideline depending on the project.

Codes and Standards

1) Addressing:

- a) Address numbers shall be posted on the building and shall be visible from the street. Said numbers shall contrast with their background. *[Addressing shall be in accordance with RCFD Standard 07-01.]* CFC 505.1

2) Electrical:

- a) Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the code official responsible for enforcement of the California Electrical Code. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used. CFC 605.1

3) Fire Alarms:

- a) Every large-family day care home shall be provided with at least one manual fire alarm box at a location approved by the authority having jurisdiction. Such device shall actuate a *fire alarm signal**, which shall be audible throughout the facility at a minimum level of 15-db above ambient noise level. These devices need not be interconnected to any other fire alarm device, have a control panel or be electrically supervised or provided with emergency power. Such device or devices shall be attached to the structure and must be a device that is listed and approved by the Office of the State Fire Marshal. CFC 907.2.6.4

1. *Fire Alarm Signal defined: A signal initiated by a fire alarm-initiating device such as a manual fire alarm box, automatic fire detector, water flow switch, or other device whose activation is indicative of the presence of a fire or fire signature. CFC 202

4) Smoke Alarms:

- a) Large-family day care homes shall be equipped with State Fire Marshal approved and listed single-station residential-type smoke alarms. CBC 455.3
- b) Where more than one smoke alarm is required, the smoke alarms shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms. CFC 907.2.11.5
- c) Locations: CFC 907.2.11.2
1. On ceilings or walls outside of each separate sleeping area in the immediate vicinity of bedrooms.
 2. In each room used for sleeping purposes.
 3. In each story within a dwelling unit, including basements but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.
- d) Existing Smoke Alarms that are identified as no longer being able to function or test appropriately, shall be replaced. The malfunctioning smoke alarm shall be replaced with a like-style smoke alarm (Battery-only or hard-wired/interconnected). The new smoke alarm shall be provided with a 10-year battery life.

5) Carbon Monoxide Alarms

- a) CBC Section 915 requires Group R occupancies located in a building containing a fuel-burning appliance or a building that has an attached garage shall be equipped with single station carbon monoxide alarms. The carbon monoxide alarms shall be listed as complying with UL 2034 and shall be installed and maintained in accordance with NFPA 720 and the manufacturer's instructions.

Exceptions:

1. Carbon monoxide detection shall not be required in dwelling units, sleeping units and classrooms where there are no communicating openings between the fuel-burning appliance or fuel-burning fireplace and the dwelling unit, sleeping unit or classroom.
2. Carbon monoxide detection shall not be required in dwelling units, sleeping units and classrooms where carbon monoxide detection is provided in one of the following locations:
 - 2.1. In an approved location between the fuelburning appliance or fuel-burning fireplace and the dwelling unit, sleeping unit or classroom.
 - 2.2. On the ceiling of the room containing the fuel-burning appliance or fuel-burning fireplace.

6) Fire Extinguisher:

- a) Large-family day care homes shall be equipped with a portable fire extinguisher having a minimum 2-A 10-BC rating. CBC 455.4
- b) Portable fire extinguishers having a gross weight not exceeding 40-pounds shall be installed so that its top is not more than 5-feet above the floor. CCR, Title 19, Sec 567.6
- c) Fire extinguishers shall be serviced on an annual basis. CCR, Title 19, Sec 575.1

7) Room Locations:

- a) Rooms used for day care purposes shall not be located above the first story. CBC 1006.2.2.7

Exception: Buildings equipped with an automatic sprinkler system throughout and which have at least one of the required exits providing access directly to the exterior. NFPA 13R may be used in large-family day care homes. The sprinkler omissions of NFPA 13R shall not apply unless approved by the authority having jurisdiction.

- b) The garage of a home is not part of the Dwelling Unit, therefore, shall not be used for day care purposes. CBC Definitions and occupancy use/classification.

8) Garage Separation:

- a) Door openings between a private garage and the dwelling unit shall be equipped with either solid wood doors or solid or honeycomb core steel doors not less than 1³/₈ inches in thickness with a fire protection rating of not less than 20 minutes. The integrity of the wall between the dwelling and the garage shall be maintained and be free of penetrations. Doors shall be self-closing and self-latching. CBC 406.3.4

9) Exiting:

- a) Every story or basement of a large-family day care home shall be provided with two exits which are remotely located from each other. Every required exit shall be of a size to permit the installation of a door not less than 32-inches in clear width and not less than 6-feet, 8-inches in height. A manually operated horizontal sliding door may be used as one of the two required exits.

Where basements are used for day-care purposes, one of the two required exits shall provide access directly to the exterior without entering the first story. The second exit from the basement may either pass through the story above or exit directly to the exterior.

Exception: Buildings equipped with an automatic sprinkler system throughout and which have at least one of the required exits providing access directly to the exterior. NFPA 13R may be used in large family day-care homes. The sprinkler omissions of NFPA 13R shall not apply unless approved by the enforcing agency.

Egress doors, including manually operated horizontal sliding doors, shall be readily openable from the inside without use of a key or special knowledge or effort. CBC 1006.2.2.7.

10) Special Hazards:

- a) Every unenclosed gas-fired water heater or furnace which is within the area used for child care in a large-family day care home shall be protected in such a way as to prevent children from making contact with those appliances. CBC 455.7

Exception: This does not apply to kitchen stoves or ovens.

11) Ignition Sources:

- a) Clearance between ignition sources, such as luminaries, heaters, flame-producing devices and combustible materials shall be maintained in an approved manner. CFC 305.1