



Riverside Office: 2300 Market St., Ste. 150, Riverside, CA 92501 Ph. (951) 955-4777 Fax (951) 955-4886  
 Palm Desert Office: 77-933 Las Montañas Rd., # 201 Palm Desert, CA 92211-4131 Ph. (760) 863-8886 (760) 863-7072

# Information Bulletin

Date Issued:	1-1-07	Revision Date:	IB # 06-05
Topic:	Determining Percentage of Slope		
Code Section:	N/A		
Author: T. Letterman, AFM	Date:	Approved: T. Hobday, FM	Date:
Sign:		Sign: On File	1-1-07

## Scope

The Riverside County Fire Department Fire Protection Planning Section (RCoFD) will apply the following requirements to assist and obtain consistency in determining the percent (%) of grade which is often necessary to comply with access road/driveway requirements. Examples are useful when using a grading plan or an actual on-site determination.

## DEFINITIONS

**RISE:** The elevation change that occurs in the horizontal distance measured. (Similar to the rise of a step)

**RUN:** The horizontal distance for which the % of grade is desired. (Similar to the depth of a step)

## GENERAL

Determining % of grade is simply dividing the rise by the run. It is recommended the % of grade be determined along the access road/driveway for each 5 feet to 10 feet of elevation change.


**1. GRADING PLAN DETERMINATION:** It is necessary to determine the distance (run) for which the % is desired and the elevation change (rise) from the contour lines.

**EXAMPLE:** Determine the distance (run) where the % of grade is desired by using the scale on the grading plan. Use the contour lines within that distance and determine the elevation change (rise).

$$21' \div 115' = .182 \text{ or } 18\% \text{ Grade (Rise) (Run)}$$

**2. ON-SITE DETERMINATION:** In the absence of a "Smart Level" the following method will determine % of grade on a slope.

**EXAMPLE:** A level (or straight board with a level on it) is held against the slope in a level position without moving. A measurement is taken at the 36 inch point down to the slope. The 36 inch point is the run and the vertical measurement taken is the rise. 36 inches is used as an example, but the longer the run, the more accurate the results.



$$7" \div 36" = .194 \text{ or } 19\% \text{ Grade}$$

Questions regarding specific applications should be directed to RCoFD Fire Protection Planning staff.